

## Appendix H - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CKL1 - Flat 121 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
4-Jan-23	15:35	Fine	74.2	77.7	61.1	72.4	70
10-Jan-23	14:38	Drizzle	72.2	75.6	65.5	72.4	72.2 Measured ≤ Baseline
16-Jan-23	14:30	Fine	72.5	75.1	62.2	72.4	56
27-Jan-23	10:57	Sunny	76.1	79.7	62.4	72.4	74



Location CKL2 - Flat 103 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
4-Jan-23	15:04	Fine	74.7	78.2	64.0	71.4	72
10-Jan-23	15:21	Drizzle	74.6	78.5	60.5	71.4	72
16-Jan-23	15:03	Fine	71.2	75.0	60.9	71.4	71.2 Measured ≤ Baseline
27-Jan-23	11:50	Sunny	76.7	80.0	63.5	71.4	75

Location KTD1 - Centre of Excellence in Paediatrics (Rooftop of Children's Hospital)							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
4-Jan-23	15:20	Sunny	75.7	79.1	71.1	78.0	75.7 Measured ≤ Baseline
10-Jan-23	11:12	Drizzle	70.3	74.0	63.3	78.0	70.3 Measured ≤ Baseline
16-Jan-23	11:16	Fine	71.6	73.1	69.7	78.0	71.6 Measured ≤ Baseline
27-Jan-23	18:00	Sunny	68.2	69.5	66.3	78.0	68.2 Measured ≤ Baseline

Location KER1 - Future Residential Development at Kerry Godown							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
4-Jan-23	16:12	Sunny	64.9	65.7	62.2	65.0	64.9 Measured ≤ Baseline
10-Jan-23	13:24	Drizzle	73.9	77.5	60.5	65.0	73
16-Jan-23	10:25	Fine	68.7	70.4	66.5	65.0	66
27-Jan-23	15:25	Sunny	67.9	69.1	66.0	65.0	65




Location KTD2d - Next to the SOR Office of Trunk Road T2 in Kai Tak Area							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
4-Jan-23	13:18	Sunny	59.9	61.9	57.0	64.0	60 Measured ≤ Baseline
10-Jan-23	10:12	Fine	73.2	76.7	62.7	64.0	73
16-Jan-23	13:05	Fine	61.6	63.1	57.6	64.0	62 Measured ≤ Baseline
27-Jan-23	14:07	Sunny	60.7	62.4	56.3	64.0	61 Measured ≤ Baseline

## Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron  Graphical Presentation of Construction Noise Monitoring Results	Date	Project	CINOTECH
	Jan 23	No. MA20003	
		Appendix H	

## Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron  Graphical Presentation of Construction Noise Monitoring Results	Date Jan 23	Project No. MA20003	
	Appendix H		