

Appendix H - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CKL1 - Flat 121 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jun-23	9:30	Drizzle	73.4	76.7	63.8	72.4	67
12-Jun-23	9:00	Sunny	73.7	77.7	62.3	72.4	68
23-Jun-23	10:04	Cloudy	73.7	77.7	62.1	72.4	68
28-Jun-23	14:05	Drizzle	73.5	77.1	61.7	72.4	67



Location CKL2 - Flat 103 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jun-23	9:33	Drizzle	74.9	78.4	62.8	71.4	72
12-Jun-23	9:32	Sunny	75.3	79.1	68.6	71.4	73
23-Jun-23	9:30	Fine	75.4	78.8	65.1	71.4	73
28-Jun-23	13:34	Fine	74.4	78.2	63.8	71.4	71

Location KTD1 - Centre of Excellence in Paediatrics (Rooftop of Children's Hospital)							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jun-23	14:15	Drizzle	68.8	69.9	67.8	78.0	68.8 Measured ≤ Baseline
12-Jun-23	13:53	Sunny	69.6	71.3	67.5	78.0	69.6 Measured ≤ Baseline
23-Jun-23	11:24	Fine	66.7	67.9	65.2	78.0	66.7 Measured ≤ Baseline
28-Jun-23	11:32	Cloudy	67.7	69.0	66.1	78.0	67.7 Measured ≤ Baseline

Location KER1 - Future Residential Development at Kerry Godown							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jun-23	13:06	Drizzle	74.1	75.8	72.6	65.0	74
12-Jun-23	11:48	Sunny	68.4	69.3	64.8	65.0	66
23-Jun-23	12:58	Cloudy	66.0	66.4	61.7	65.0	59
28-Jun-23	10:41	Cloudy	64.7	65.9	63.0	65.0	64.7 Measured ≤ Baseline




Location KTD2d - Next to the SOR Office of Trunk Road T2 in Kai Tak Area							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jun-23	15:56	Drizzle	69.2	70.8	64.6	64.0	68
12-Jun-23	15:56	Sunny	62.0	62.9	59.2	64.0	62 Measured ≤ Baseline
23-Jun-23	14:04	Fine	58.0	59.5	55.1	64.0	58 Measured ≤ Baseline
28-Jun-23	9:30	Drizzle	59.2	60.6	56.3	64.0	59 Measured ≤ Baseline

Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Date	Project No.	CINOTECH
	Jun 23	MA20003	
		Appendix H	

Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Date Jun 23	Project No. MA20003	
		Appendix H	