

## Appendix H - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CKL1 - Flat 121 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
2-Nov-23	14:00	Fine	74.4	78.9	62.8	72.4	70
8-Nov-23	13:36	Cloudy	72.5	76.1	62.2	72.4	56
14-Nov-23	15:00	Sunny	74.2	76.8	70.8	72.4	70
21-Nov-23	10:09	Fine	74.8	78.6	65.5	72.4	71
30-Nov-23	10:46	Cloudy	76.5	80.4	63.0	72.4	74



Location CKL2 - Flat 103 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
2-Nov-23	14:35	Fine	71.7	75.1	64.2	71.4	60
8-Nov-23	14:09	Cloudy	74.5	77.5	62.2	71.4	72
14-Nov-23	16:09	Sunny	71.6	75.9	66.8	71.4	58
21-Nov-23	10:42	Sunny	76.4	79.6	66.0	71.4	75
30-Nov-23	11:50	Cloudy	75.6	79.2	62.6	71.4	74

Location KTD1 - Centre of Excellence in Paediatrics (Rooftop of Children's Hospital)							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
2-Nov-23	10:45	Fine	71.5	72.5	70.4	78.0	71.5 Measured ≤ Baseline
8-Nov-23	17:33	Cloudy	66.1	67.6	64.7	78.0	66.1 Measured ≤ Baseline
14-Nov-23	11:28	Sunny	69.5	71.2	67.6	78.0	69.5 Measured ≤ Baseline
21-Nov-23	12:57	Sunny	71.4	73.8	68.4	78.0	71.4 Measured ≤ Baseline
30-Nov-23	13:56	Sunny	71.6	73.8	68.9	78.0	71.6 Measured ≤ Baseline

Location KER1 - Future Residential Development at Kerry Godown							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
2-Nov-23	11:30	Fine	67.0	67.3	64.6	65.0	63
8-Nov-23	16:28	Cloudy	69.1	70.6	67.7	65.0	67
14-Nov-23	13:45	Sunny	67.5	68.4	66.5	65.0	64
21-Nov-23	13:45	Sunny	68.6	71.2	64.4	65.0	66
30-Nov-23	13:04	Fine	69.5	72.1	65.1	65.0	68




Location KTD2d - Next to the SOR Office of Trunk Road T2 in Kai Tak Area							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
2-Nov-23	9:30	Fine	61.4	62.8	58.5	64.0	61 Measured ≤ Baseline
8-Nov-23	18:42	Cloudy	54.9	55.6	51.2	64.0	55 Measured ≤ Baseline
14-Nov-23	10:32	Sunny	62.1	65.1	58.4	64.0	62 Measured ≤ Baseline
21-Nov-23	11:40	Sunny	64.7	66.3	57.8	64.0	56
30-Nov-23	15:07	Fine	64.4	66.4	59.9	64.0	54

## Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron  Graphical Presentation of Construction Noise Monitoring Results	Date	Project	CINOTECH
	Nov 23	No. MA20003	
		Appendix H	

## Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron  Graphical Presentation of Construction Noise Monitoring Results	Date Nov 23	Project No. MA20003	
		Appendix H	