

Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CM1 - Nga Lai House, Yau Lai Estate Phase 1, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
5 Oct 2023	15:28	Sunny	69.4	70.6	68.2	65.5	67
11 Oct 2023	9:00	Fine	69.5	70.6	68.0	65.5	67
17 Oct 2023	13:00	Fine	69.4	70.9	68.3	65.5	67
27 Oct 2023	9:00	Sunny	68.8	70.3	67.7	65.5	66




Location CM2 - Bik Lai House, Yau Lai Estate Phase 1, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
5 Oct 2023	14:46	Sunny	69.3	70.6	67.8	63.6	68
11 Oct 2023	13:29	Fine	68.8	68.9	67.2	63.6	67
17 Oct 2023	11:38	Fine	70.5	72.0	68.8	63.6	70
27 Oct 2023	12:30	Fine	69.9	71.0	68.0	63.6	69

Location CM3 - Block S, Yau Lai Estate Phase 5, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
5 Oct 2023	12:48	Sunny	67.7	69.6	65.6	65.6	64
11 Oct 2023	12:44	Fine	66.5	67.7	64.9	65.6	59
17 Oct 2023	11:00	Fine	68.5	70.1	64.9	65.6	65
27 Oct 2023	11:37	Sunny	67.8	69.9	66.0	65.6	64

Location CM4 - Tin Hau Temple, Cha Kwo Ling							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
5 Oct 2023	9:00	Sunny	58.3	61.2	52.5	62.0	58 Measured ≤ Baseline
11 Oct 2023	11:07	Fine	57.7	56.3	53.8	62.0	58 Measured ≤ Baseline
17 Oct 2023	9:00	Fine	58.0	61.1	53.9	62.0	58 Measured ≤ Baseline
27 Oct 2023	9:00	Sunny	59.9	61.5	53.5	62.0	60 Measured ≤ Baseline



Location CM5 - CCC Kei Faat Primary School, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
5 Oct 2023	13:45	Sunny	67.9	70.4	63.4	68.2	68 Measured ≤ Baseline
11 Oct 2023	12:01	Fine	66.9	69.9	62.1	68.2	67 Measured ≤ Baseline
17 Oct 2023	10:00	Fine	68.0	70.3	62.9	68.2	68 Measured ≤ Baseline
27 Oct 2023	13:55	Sunny	67.1	69.8	64.0	68.2	67 Measured ≤ Baseline

Noise Levels



Title Contract No. ED/2018/04 Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Scale	Project	CINOTECH
	N.T.S	No. MA20003	
	Date Oct 23	Appendix G	

Noise Levels



Notes:

- 1) The major activitie(s) being carried out on site during the reporting period is/are presented in Section 1.10
- 2) The weather conditions during the reporting month are presented in Appendix C.
- 3) Other factors which might affect the monitoring results are presented in Section 3.13.

Title Contract No. ED/2018/04 Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Scale	Project	CINOTECH
	N.T.S	No. MA20003	
	Date	Appendix	
	Oct 23	G	